

Town of Saltcoats
RFP
Design / Build Town Shop

ADDENDUM 2

Article 1 Acceptance of Proposals

Article 3 of Instructions to Proponents

Delete “thirty (30) days”. And Replace with “sixty (60) days”

Article 11 of Instructions to Proponents

Delete “thirty (30) days”. And Replace with “sixty (60) days”

Article 2 More Information

- Excess soil will be disposed of on-site.
- Fire suppression is not required.
- Millwork is not required.
- Fencing is not required.
- Bollards are required at overhead door entrances.
- Signage utilizing single letters with flood light shall be provided.
- Overhead doors shall be powered.
- Exterior lighting shall be wall packs, no pole lights.